

ZONING STAFF MEETING

Department of Public Utilities Comments

CASE NAME: Westhaven Properties, LLC

PROJECT #: SE2023-00019

PLEASE MARK THE APPROPRIATE BOX BELOW:

No Comment:

Comments Below:

DATE: 7/14/2023

REVIEWED BY: T. Watkins

The Hanover County Department of Public Utilities (DPU) has reviewed the above referenced request for special exception and has the following comments:

1. A private RPZ will be required on the domestic water service for each townhome unit over 3-story high.

Please feel free to contact me if you have any questions or concerns.